



Hubbell Building Automation  
Low Voltage Sensors (devices)  
**Requires 33mA each**

**NOTE:**

1. DO NOT attempt to power more than 4 devices, be it sensors or slave packs, from a single power pack.

1 circuit with up to 4 sensors and UVPP



**Building Automation, Inc.**